






REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED
—	—	—	—	—



	*MANUFACTURER	*PART NUMBER	DESCRIPTION	QUANTITY
171	Autonics	LE4S	Digital Timer, 24-240VAC/VDC, Relay Output	1
172	Autonics	PG-08	8-Pin Socket	1
173	Eurobox (EXM)	5412 ES161608	Enclosure, 16" x 16" x 8"	1
	Emerson-Sola	SVL 2-24-100	Power Supply, Input 100-240VAC, Output 24VDC @2.1A	1
174	WEG	CFW300A06P052NB20	WEG CFW300 VFD, 1.5HP @ 230VAC 1-PHASE	1
	Sprecher+Schuh	D7P-POT5A	Potentiometer, 5K	1
175	Sprecher+Schuh	D7P-E202PX01	Pushbutton, Extended Black "STOP", 1NC	1
176	Sprecher+Schuh	D7P-F301PX10	Pushbutton, Flush Green "START", 1NO	1
	Sprecher+Schuh	D7P-MT44	E-Stop Operator, Twist-To-Release, 40mm	1
177	Sprecher+Schuh	D7-ALP	Latch, Plastic	1
178	Sprecher+Schuh	D7-X01S (D7-X01)	Contact Block, NC	1
	WEG	MSW 40 B-3 H	Base Mounted 3 Pole Switch w/Handle & Shaft	1
179	WEG	MSW HS 185-40	Metal Operating Shaft	1
180	Sprecher+Schuh	D7-15YSE112	E-Stop Inscription Ring	1
	Sprecher+Schuh	L9-15/2/D	Circuit Breaker, 15Amp, D-Curve	1
181	Sprecher+Schuh	L8-2/2/B	Circuit Breaker, 2Amp, B-Curve	1
182	Sprecher+Schuh	L8-2/1/B	Circuit Breaker, 2Amp, B-Curve	1
	Iboco	OMEGA 3FAL1	DIN Rail, 35mm x 1meter	1
183	Iboco	T1-0510G	WIRE DUCT, 0.50" x 1.0" x 2M	1
184	Sprecher+Schuh	V7-WG4	Ground Terminal	2
	Sprecher+Schuh	V7-W4	Terminal	11
185	Sprecher+Schuh	V7-EA35	End Anchor	11
186	Sprecher+Schuh	V7-EB3	End Barrier	2
187	Sprecher+Schuh	V7-PP3	Partition	2
	Sprecher+Schuh	V7-SM6X12	Marker Card	1
188	Sprecher+Schuh	V7-CJ6-2	Center Jumper	2
189	McMaster-Carr	5891T111	Electrical Hazard Warning Label, 1-3/4"W x 2-1/2"H	1
			Legend Plate, 0.75" x 0.75", "0"	1
190			Legend Plate, 0.75" x 0.75", "I"	1
191			Legend Plate, 0.75" x 2.00", "MOTOR SPEED CONTROL"	1
192				
193	*FUNCTIONALLY EQUIVALENT COMPONENTS MAY BE SUBSTITUTED			

TIMER SETTINGS		
PARAMETER	DISPLAY	SETTING
Output operation mode	OUTN	OND
Time Range	ERRG	99 ^h 59 ^m
Time UP/DOWN	U-D	DN
Width of min. input signal	1nL	20
Backlight	bLU	ON
Key lock	LOCK	LOFF

195

196

197

198

199

DRAWN BY PCW CHKD BY PCW DATE DRAWN 04/11/25 DATE CHKD 04/11/25	MORSE The Specialist In Drum Handling Equipment 103 Kuhn Rd, Syracuse, NY 13208 PHONE 315-564-4347 FAX 315-437-1029										
THIS MATERIAL IS THE EXCLUSIVE PROPERTY OF MORSE MANUFACTURING COMPANY INC. AND MUST BE RETURNED TO MORSE IMMEDIATELY UPON REQUEST. THIS MATERIAL AND INFORMATION ILLUSTRATED OR CONTAINED HEREIN MAY NOT BE REPRODUCED, COPIED, USED, OR TRANSMITTED IN WHOLE OR IN PART IN ANY MANNER WITHOUT THE PRIOR WRITTEN CONSENT OF MORSE MANUFACTURING COMPANY INC.	<table><tr><td>TITLE</td><td>MORSE</td><td>DWG NO.</td><td>SHEET</td><td>REV</td></tr><tr><td>7009-P VFD PANEL (ELECTRICAL)</td><td></td><td>AACI041125A</td><td>1 of 1</td><td>00</td></tr></table>	TITLE	MORSE	DWG NO.	SHEET	REV	7009-P VFD PANEL (ELECTRICAL)		AACI041125A	1 of 1	00
TITLE	MORSE	DWG NO.	SHEET	REV							
7009-P VFD PANEL (ELECTRICAL)		AACI041125A	1 of 1	00							